

FIRE SAFETY CERTIFICATE

No. 230622/01

Dated: 23/06/2026

Certified that the **SRI SRI ACADEMY SILIGURI BLOCK-I & II** (name of the building or premises at **DHUKURIA, MATIGARA, DARJEELING WEST BENGAL** (address) comprised of **ZERO** basement(s) and **(G+2) STORIED OVER ROOF TRUSS** (upper floors) owned/ occupied by **SRI SRI ACADEMY SILIGURI** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 10.02.2023 (date of inspection) in the presence of **Shahab Anjum Dhukuria post new chumta siliguri** (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes XII (X/ XII) With effect from .03.2023 for a period of **03 year (March 2029)** year in accordance with rule and subject to compliance of specific conditions as appended: -

1. Fire and smoke doors at the entrances of all the staircase enclosures as marked in the plan at each floor level shall be provided.
2. Underground water reservoir having water capacity of 150000 ltrs. and overhead water reservoir having capacity of 10000 ltrs. exclusively for fire fighting purpose with replenishing arrangements @ 1000 ltrs/min. preferably from two different sources of water supply shall be provided.
3. Provision for Hose Reel in conjunction with wet riser shall be made at each floor of the building level from the underground reservoir through main pump conforming the relevant I.S. specification.
4. Manually operated Electrical Fire Alarm System with at least three numbers of break glass type call boxes fitted with Hooters along with Public Address System at each floor connecting with visual panel board shall be made in Control Room., Arrangement shall have to be made to supply of power with the help of generator to operate at least fire pump

Issued on 23/06/2026 (date of issue) at Siliguri west Bengal (Place) by Government of west Bengal(Fire & Emergency Service)

*Strike out whichever is not applicable.

Signature with Seal:  Divisional Fire Officer

Name : West Bengal Fire & Emergency Service

Designation : Darjeeling Division

To
SRI SRI ACADEMY SILIGURI
Dhukuria, Matigara Dist Darjeeling West
Bengal -734009
(Name & Address of the Institution)

Name & Address of Department/ Office:

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Narendra Thota
Principal

Sri Sri Academy, Siliguri
Dhukuria, P.O. New Chumta, Dagapur, Pin-734009
Affiliation No. 2430273, School No. 15926